

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 25/2026-27

Dated: 29/01/2026

It is certified that an inspection team headed by Venkatesh H, Senior Analyst

(Name of Officers with designation) from RDW & SD PHED

inspected the Sri Chaitanya techno school, HBRpd Extension, Kotlitlopur

(Name & Address of the school) on 29/01/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. TUM26JAN0263 dated 30/01/2026

of RDW & SD water quality (PHED Lab) certified that

the Sri Chaitanya techno school (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 29/01/2027

Signature with Seal: Venkatesh H

Name: Venkatesh H

Designation: Senior Analyst

Name & Address of the Office / Department: R.D.W. & S.D.

To

(Name & Address of the Institution)

Water Testing Laboratory
Zilla Panchayath Building,
TUMAKURU - 572 101

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Tumkur District Water Quality Testing Laboratory

TC- 14841

Zilla Panchayath Compound B.H Road Tumkur - 572101, Karnataka.

Email: rdwsd.wqmstp.tumkurdistrictlab@gmail.com

TEST REPORT

Sri Chaitanya Techno School,
Horpet Extension, Kothithopu,
Tumkur-572102

Name & Contact No : Krishna Rao:7618712599

Sample Collected By: Customer

Reference: TRF

Sample code:TUM26JAN0263

ULR No. : TC- 1484126000000263F

Date of Sample collection:29/01/2026

Sample receipt date: 29/01/2026

Analysis start date:30/01/2026

Analysis completion date: 30/01/2026

Report date: 30/01/2026

Sampling Method: APHA24th Edition

Sample Particulars :Drinking Water

Sample quantity:1 Liter

Sl. No	Test	Test Method	Detectable Limit	Acceptable Limit IS 10500 :2012	Permissible Limit IS 10500 : 2012 RA-2018	Results	Units
Description: Colourless liquid.							
1.	pH Value at 24.4°C	IS 3025 (Part-11) : 2022	2-14	6.5 – 8.5	No relaxation	6.93	-
2.	Electrical Conductivity, at 24.6°C	IS 3025 (Part-14) :2019	1.0	—	—	145	µS/cm
3.	Odour	IS 3025 (Part-5 & 6):2018	-	Agreeable	Agreeable	Agreeable	-
4	Taste	IS 3025 (Part-7 & 8):2023	-	Agreeable	Agreeable	-	-
5.	Colour	IS 3025 (Part-4) :2023	1	5	15	<1	H _z
6.	Turbidity	IS 3025 (Part-10) : 2023	0.5	1	5	<0.5	NTU
7.	Total Dissolved Solids @ 180°C	IS 3025 (Part-16) : 2023	16	500	2000	84	mg/l
8.	Alkalinity as CaCO ₃	IS 3025 (Part-23) : 2023	20	200	600	35	mg/l
9.	Total Hardness as CaCO ₃	IS 3025 (Part-21) : 2019	20	200	600	44	mg/l
10.	Calcium as Ca	IS 3025 (Part-40) : 2024	8.0	75	200	12	mg/l
11.	Magnesium as Mg	IS 3025 (Part-46) : ,2023	5.0	30	100	<5	mg/l
12	Chloride as Cl	IS 3025 (Part-32) : 2019	10	250	1000	26	mg/l
13.	Sulphate as SO ₄	IS 3025 (Part-24/Sec 1) : 2022	1.0	200	400	5.0	mg/l
14.	Fluoride as F, mg/l	APHA 24 th Edition 4500- F D	0.1	1	1.5	<0.1	mg/l
15.	Nitrate as NO ₃ , mg/l	APHA 24 th Edition 4500- NO ₃ B	1.0	45	No relaxation	3.5	mg/l
16.	Iron as Fe, mg/l	IS 3025 (Part-53) : 2024	0.1	1	No relaxation	<0.1	mg/l

Reviewed & Authorized By

Venkatesh .H

Technical Manager

Note:

- The above results relate only to the sample tested.
- The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- Samples will be discarded after 7 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

-: End of Report:-

R.D.W. & S.D.
Water Testing Laboratory
Zilla Panchayath Building,
TUMAKURU - 572 101